

APPENDIX-L
FORM 'S'
Fire Audit Report
Year 2026-27

REF- FIRE/14/09/2604

To

M/S SKS International School

Address : Gram dehri , infront of IIM rau Pithampur road indore madhya pradesh 453331
VALIDITY: 24/09/2027

Sub.: Submission of fire audit report certification **SKS INTERNATIONAL SCHOOL**, I KRISHNA JATAV (Name of the Fire Engineer) have inspected your Factory/Industry/Hospital building /Premises plot area 22482 SQFT on 24/09/2026 Date and checked all Fire Equipment's/ installation and have completed the Fire Audit of the said building. 2. Details of fire system installed are as below:

Dear Sir/Madam,

Details of fire system installed are as below:

S. No	Particular	Available/Installation Or Not installed (as per requirements give comments)	Comments for working of system (Attach details, if needed)
1	Access	Sufficient space Available for fire brigade	18 Mtr Wide Road 2 means of escape
2	Wet riser	Not Required	
3	Down comer	Suggestion	
4	Hose reel	Suggestion	
5	Automatic sprinkler system	NOT REQUIRED	
6	Yard hydrant	Suggestion	
7	Underground tank with draw off connection	Available	20 KL TANK
8	Terrace tank	Available	10 KL Tank
9	Fire Pump	Suggestion	
10	Terrace pump	Not Required	
11	First aid firefighting appliances	Installed	As per IS 2190
12	Pressurization system	Naturally Ventilated	
13	Auto detection system	Not Required	

14	Manual operated electrical fire alarm system	Installed	
15	P.A system with talk back facility	Not Required	
16	Emergency light	Installed	
17	Auto D.Gset	Not Required	
18	Illuminated exit sign	Available	
19	Means of escape	Available	02 escapes in premises
20	Compartmentation	Not Required	
21	MCB/ELCB	Installed as per IS 60898	
22	Fireman switch in lift	Not Required	
23	Hose boxes with delivery hose and branch	Suggestion	
24	Refuge area	Not Required	
25	Any other installation		

It is certified that the Installed Fire system as given above are in working condition and safe

Date: - 24/09/2026

Digitally
signed by
KRISHNA
Signature
Date:
2026.09.24
11:14:43
L. No: FIRE/31

MOB. NO: 9685747450